

2016 Bi-Weekly Sampling

<u>Date</u>	<u>Address</u>	<u>T.C.</u>	<u>E.C.</u>	Chlorine (mg/L)	
				<u>Free</u>	<u>Total</u>
January 5th	19 Vista Cove	0	0	0.73	0.89
	Water Plant	0	0	0.77	0.92
January 19th	Arena	0	0	0.69	0.81
	Water Plant	0	0	0.79	0.94
February 2nd	202 Carnoustie Cove	0	0	0.69	0.81
	Water Plant	0	0	0.77	0.90
February 17th	22 Wyldeewood Cres	0	0	0.76	0.89
	Water Plant	0	0	0.78	0.94
March 1st	Arena	0	0	0.68	0.79
	Water Plant	0	0	0.74	0.85
March 15th	69 Cobblestone Court	0	0	0.75	0.91
	Water Plant	0	0	0.78	0.93
March 29th	27 Ellington Way	0	0	0.72	0.88
	Water Plant	0	0	0.74	0.90
April 12th	318 Troon	0	0	0.53	0.67
	Water Plant	0	0	0.72	0.91
April 27th	44 Ellington Way	0	0	0.62	0.79
	Water Plant	0	0	0.63	0.78
May 10th	Arena	?	?	0.82	1.03
	Water Plant	?	?	1.24	1.44
May 12th	48 Hampton Drive	0	0	0.99	1.29
	Water Plant	0	0	0.76	0.93
May 25th	113 Saint Andrew's Way	0	0	0.79	1.04
	Water Plant	0	0	0.96	1.20
June 7th	302 Troon Cove	0	0	0.90	1.14
	Water Plant	0	0	0.95	1.30

June 21st	6 Errington Way	0	0	0.91	1.19
	Water Plant	0	0	0.93	1.21
July 6th	15 Vista Cove	0	0	0.88	1.12
	Water Plant	0	0	0.86	1.12
July 19th	17 Cobblestone Court	0	0	0.85	1.16
	Water Plant	0	0	0.84	1.16
August 2nd	Arena	0	0	0.80	0.89
	Water Plant	0	0	0.94	1.22
August 16th	Splash Pad	0	0	0.89	1.07
	Water Plant	0	0	1.00	1.31
August 30th	16 Carling Circle	0	0	0.85	1.06
	Water Plant	0	0	0.82	1.18
September 13th	Arena	0	0	0.83	0.89
	Water Plant	0	0	0.89	1.09
September 27th	23 Bentley Place	0	0	0.92	1.12
	Water Plant	0	0	0.99	1.13
October 11th	25 Vista Cove	0	0	0.86	1.03
	Water Plant	0	0	0.88	1.07
October 25th	19 Denby Cove	0	0	0.90	0.99
	Water Plant	0	0	0.87	1.08
November 8th	20 Landsbury Lane	0	0	0.90	1.00
	Water Plant	0	0	0.80	1.05
November 22nd	126 Saint Andrew's Way	0	0	0.86	1.12
	Water Plant	0	0	0.92	1.15
December 8th	Arena	0	0	0.86	0.90
	Water Plant	0	0	0.89	1.02
December 21st	19 Vista Cove	0	0	0.98	1.04
	Water Plant	0	0	0.96	1.20

Power Outage at ALS Labs - Resample needed