

## 2017 Bi-Weekly Sampling

<u>Date</u>	<u>Address</u>	<u>T.C.</u>	<u>E.C.</u>	Chlorine (mg/L)	
				<u>Free</u>	<u>Total</u>
January 4th	Raw Water	0	0	0	0
	Arena	0	0	0.81	0.86
	Water Plant	0	0	0.83	0.97
January 17th	Raw Water	0	0	0.00	0.00
	44 Cobblestone Court	0	0	0.99	1.18
	Water Plant	0	0	0.99	1.18
January 24th	Water Plant	0	0	0.86	0.98
	Arena	0	0		
	17 Vista Cove	0	0		
January 25th	Water Plant	0	0	0.88	1.02
	117 Saint Andrew's Way	0	0		
	40 Claremont Drive	0	0		
February 1st	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.76	0.83
	Water Pant	0	0	0.80	0.93
February 14th	Raw Water	0	0	0.00	0.00
	15 Wyndham Court	0	0	0.78	0.87
	Water Plant	0	0	0.82	0.92
March 1st	Raw Water	0	0	0.00	0.00
	Arena	0	0	2.20	2.20
	Water Plant	0	0	1.71	1.74
March 14th	Raw Water	0	0	0.00	0.00
	90 Cobblestone Court	0	0	0.70	0.78
	Water Plant	0	0	0.97	1.14
March 28th	Raw Water	0	0	0.00	0.00
	2 Arena Road	0	0	0.72	0.87
	Water Plant	0	0	0.79	0.90
April 11th	Raw Water	4	0	0.00	0.00
	Landsbury Lane Hydrant	0	0	0.73	0.99

	Water Plant	0	0	0.98	1.08
April 25th	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.71	0.74
	Water Plant	0	0	0.70	0.79
May 9th	Raw Water	1	0	0.00	0.00
	10 Andover Place	0	0	0.97	1.09
	Water Plant	0	0	0.96	1.09
May 23rd	Raw Water	0	0	0.00	0.00
	101 Saint Andrew's Way	0	0	0.77	0.87
	Water Plant	0	0	0.76	0.83
June 6th	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.73	0.79
	Water Plant	0	0	0.94	1.07
June 20th	Raw Water	0	0	0.00	0.00
	Splash Pad	0	0	0.94	1.17
	Water Plant	0	0	0.93	1.08
July 4th	Raw Water	0	0	0.00	0.00
	47 Wyndham Court	0	0	0.91	0.97
	Water Plant	0	0	0.97	1.05
July 18th	Raw Water	0	0	0.00	0.00
	107 Breckenridge Drive	0	0	0.91	0.97
	Water Plant	0	0	0.87	0.95
August 1st	Raw Water	0	0	0.00	0.00
	15 Vista Cove	0	0	0.86	1.04
	Water Plant	0	0	0.93	1.04
August 15th	Raw Water	0	0	0.00	0.00
	Splash Pad	0	0	0.92	1.01
	Water Plant	0	0	0.92	1.06
August 29th	Raw Water	9	0	0.00	0.00
	Arena	5	0	0.92	1.03
	Water Plant	0	0	0.93	1.09
	RE-SAMPLE NEEDED				

August 30th	Arena	0	0	0.92	1.00
	101 Saint Andrew's Way	0	0	0.90	1.02
	302 Troon Cove	0	0	0.82	0.88
September 12th	Raw Water	0	0	0.00	0.00
	Splash Pad	0	0	1.05	1.15
	Water Plant	Unknown	Unknown	1.04	1.20
	Lab Accident on WP sample				
September 13th	Water Plant	0	0	1.07	1.20
September 26th	Raw Water	0	0	0.00	0.00
	15 Vista Cove	0	0	0.89	1.00
	Water Plant	0	0	0.84	0.94
October 10th	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.87	0.96
	Water Plant	0	0	0.84	1.02
October 24th	Raw Water	0	0	0.00	0.00
	117 Saint Andrew's Way	0	0	0.70	0.80
	Water Plant	0	0	0.90	1.03
November 7th	Raw Water	0	0	0.00	0.00
	10 Andover Place	0	0	0.84	0.95
	Water Plant	0	0	0.90	1.00
November 21st	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.84	0.94
	Water Plant	0	0	0.83	0.96
December 5th	Raw Water	0	0	0.00	0.00
	Arena	0	0	0.88	0.92
	Water Plant	0	0	0.92	1.06
December 19th	Raw Water	0	0	0.00	0.00
	309 Bronstone Drive	0	0	0.79	0.91
	Water Plant	0	0	0.99	1.15